



The highlighted sections of the 6" DG header pipe to be televised.

- NOTES:
1. LIGHTING POLE 26' HIGH 6" ARM WITH 250 WATT 300 HZ MERCURY VAPOR FIXTURE TO MATCH EXISTING FIXTURES.
 2. FOR CONCRETE BASE SEE DWG. 301-011 (22)
 3. DIRECT BURIAL CABLE SHALL BE BURIED MIN. 30" BELOW GRADE.
 4. CONTRACTOR TO SAW CUT EXISTING ROADWAY PAVEMENT, INSTALL CONDUIT, AND RESTORE PAVEMENT TO ORIGINAL CONDITION AFTER CONDUCTORS HAVE BEEN INSTALLED OR, AT CONTRACTOR'S OPTION, PUSH OR JACK A 2" RIGID GALVANIZED STEEL CONDUIT UNDER EXISTING PAVEMENT.

RECORDED
 FEB 03
 763
 01/10

DATE IS ONE INCH ON ORIGINAL DRAWING.
 IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY.

DSGN C.J.
 DR *vev*
 CHK J.C.H.
 APVD *DR*

THIS DESIGN PREPARED FOR CH2M-HILL, INC. (PRIME CONSULTANT TO MILWAUKEE METROPOLITAN SEWER DISTRICT) BY:
Donohue
 Engineers and Architects

NO.	DATE	REVISION	BY	APVD
1	9-18-81	GENERAL REVISIONS		

SEWERAGE COMMISSION OF THE CITY OF MILWAUKEE
**SOUTH SHORE WASTEWATER TREATMENT PLANT
 DIGESTER CONVERSION AND DIGESTER GAS STORAGE
 ELECTRICAL SITE PLAN**

OWN NO: 801-E-1
 SHEET 19 OF 116
 DATE: JUNE 20, 1991
 PROJ ID: 520031
 FILE: 01-100

FOR BIDDING AND CONSTRUCTION
 380-E-1

580-E-1