



ADDENDUM NO. 1
To the
CONTRACT DOCUMENTS
For

JONES ISLAND WATER RECLAMATION FACILITY
BLDG 278 HVAC REPLACEMENT
VEOLIA WATER MILWAUKEE LLC
PUBLIC BID NO. 13606

December 22, 2011

To All Planholders

The following changes, additions and/or deletions are hereby made a part of the Contract Documents for the Jones Island Reclamation Facility, Bldg 278 HVAC Replacement, Veolia Water Bid No. 13606 as fully and completely as if the same were fully set forth therein:

Agreement, Schedule A

ADD:

The ERV unit inside the building requires heresite coating the same as the outdoor condenser unit;
There is no Ethernet in the building to provide SCADA information to the Powerhouse.

See the Line Set Detail on Drawing M-3. Terminate one end as close as possible to the condenser as long as the fittings are accessible. Terminate the other end 6 feet above grade. The PVC pipe is only to protect the refrigerant piping from damage.

The stored items around the unit on the mezzanine will be moved by VWM to accommodate removal and installation.

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1, consisting of 1 page(s), by signing in the space provided and submitting the signed Addendum with the Bid. Bids submitted without this Addendum may be considered non-responsive.

Sincerely,

Barbara L. Brown
Procurement Manager

Receipt acknowledged and conditions agreed to

This, the _____ day of _____, 20____

Company Name

Signature of Contractor

Print Name of Contractor